

ISIFLO Byggesystem / ISIFLO building brick system

Eksempel 1 / example 1:

Reduktion eller ombygning til indvendig eller udvendig rørgvind /
reduction or rebuilding to female or male threads:

Omløbsmøtrik, klemring og trykkring fjernes. O-ringen skal forblive i koblingen /
Remove the nut, grip ring and the compression ring. Leave the O-ring inside the coupling.

Ny indsats del skrues ind til anslag / *install the new part.*



Eksempel 2 / example 2: Albue / elbow 40mm x 1 1/2"

Bruk / use: Type 120 40 x 40mm
 + Type 146 40mm x 1 1/2"
 = Albue / elbow 40 mm 1 1/2"

Omløbsmøtrik, klemring og trykkring fjernes. O-ringen skal blive
i koblingen / *Remove the nut, grip ring and the compression ring.*
Leave the O-ring inside the coupling.

Ny indsats del skrues ind til anslag / *install the new part.*

